

Approval Number: 1511533
Test Report: MAT/LAB 705J



18th April 2016

P C Chanda & Co. PVT Ltd.
Ravi Auto House,
6th Floor,
103 Park Street,
Kolkata - 700 016,
India

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

BITUMINOUS BASED PRODUCTS - SMALL SURFACE AREA CONTACT ONLY.

5021

'Sealcoat Black'. Black coloured, factory applied petroleum bituminous coating. Spray apply a single coat to 35 microns (Dry Film Thickness) before curing for 18 hours at 30°C. For use with water up to 23°C. This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval. Petroleum or asphaltic bitumen, NOT coal tar bitumen. Materials listed in this section are not approved for use for contact with water that is required to be wholesome on large water retaining structures such as lining of pipes, cisterns or water storage tanks.

APPROVAL NUMBER: 1511533

APPROVAL HOLDER: P C CHANDA & CO. PVT LTD.

The Scheme reserves the right to review approval.
Approval 1511533 is valid between November 2015 and November 2020

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme